Operations Update

<u>Plant Operations</u> – Plant operations and treatment were good during the month of July.

<u>Compliance Maintenance Annual Report</u> – See DNR's response (attached)

<u>United Liquid Waste Haulers</u> – As soon as the fields dry up from the recent rain United Liquid waste will start hauling.

<u>Seven Oaks Land Rental</u> - No update.

Maintenance Update

ATAD Jet Mix Pumps - Received impellers, and side plates,

Peak Flow Pump #3 VFD - No update.

DAFT Pressure Vessel Tanks - The pressure vessels are on order.

<u>Heating/Air Conditioning Unit</u> – This unit will be replaced during the upcoming filter project, so no need to replace it now. The heating part of the unit is still operable.

Kevin Skogman
Director of Operations & Maintenance

Compliance Maintenance Annual Report

Heart Of The Valley Metro Sewerage District

Last Updated: Reporting For:

6/15/2022 2021

ONR Response to Re	solution or Owner's Statement	
Name of Governing		
Body or Owner:	Heart of the Valley Metropolitan Sewerage District	
Date of Resolution or	reart of the valley Metropolitan Sewerage District	
Action Taken:		
	2022-06-14	
Resolution Number:	Loo.	
D	199	
Date of Submittal:	6/15/2022	
	THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR grade A or B. Required for grade C, D, or F):	
Permittee Response:	35. Grade – D	
meters were run concurr flowmeter registered abo	of its ultrasonic flowmeters with new laser flowmeters by early 2020. The rently for the remainder of 2020 and the main plant laser influent out 11% more flow than the ultra sonic meter that it replaced. The flowmeters and adopted the laser meters for billing and DMR reporting	
compared against its rate	nt meter replacement, the District's calculated loadings increased when sed plant BOD capacity. The flow difference was enough to put the District pacity 8 times and over 100% of its rated BOD capacity 3 times in 2021.	
with BOD indicates that the District along with its containing applying for an increase completed and the data rerating, we would anticitive.	roduce permit complaint effluent while being mathematically overloaded the rated capacity of the biological process is likely under rated. The nsultant are evaluating a stress test of the biological system and may be in the organic rating of the facility. The stress test has not been is still being evaluated. If District were to apply for and receive a ipate that near future CMAR reports would not have the points applied to and no further response would be necessary.	
I agree with your rationa	ale.	
Effluent Quality: BOD: Gr Permittee Response:	rade = A	
DNR Response:		
Effluent Quality: TSS: Gra	ade = A	
Permittee Response:		
DNR Response:		
Divin Responser		
Effluent Quality: Ammonia	a: Grade = A	
Permittee Response:	w. 	
DNR Response:		

Compliance Maintenance Annual Report

Heart Of The Valley Metro Sewerage District Last Updated: Reporting For: 6/15/2022 2021 Effluent Quality: Phosphorus: Grade = A **Permittee Response: DNR Response:** Biosolids Quality and Management: Grade = A **Permittee Response: DNR Response:** Staffing: Grade = A**Permittee Response: DNR Response:** Operator Certification: Grade = A **Permittee Response: DNR Response:** Financial Management: Grade = A **Permittee Response: DNR Response:** Collection Systems: Grade = A (Regardless of grade, response required for Collection Systems if SSOs were reported) **Permittee Response: DNR Response:** ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL **GRADE POINT AVERAGE AND ANY GENERAL COMMENTS** (Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00) G.P.A. = 3.76**Permittee Response: DNR G.P.A. Response: DNR CMAR Overall Response:** Thank you for submitting the 2021 CMAR on time. The Department appreciates your effort to protect human health and the environment by ensuring that your wastewater collection and

DNR Reviewer: Oumarou, Barti

treatment systems are properly operated and maintained. Great Job!

Phone: (920) 424-4013 Address: 625 E County Road Y, Suite 700, Oshkosh, WI 54901 **Date:** 7/28/2022