

Village of Combined Locks

2015 Flow Data

DAILY AVERAGE FLOW VOLUME (MGD):	0.31	
PEAK MONTHLY FLOW VOLUME (MGD):	0.56	
PEAK HOURLY FLOW VOLUME (MGD):	3.75	
PEAKING FACTOR RATIO (PEAK MONTHLY:ANNUAL DAILY AVERAGE):		1.79
PEAKING FACTOR RATIO (PEAK HOURLY:ANNUAL DAILY AVERAGE)		12.04

TOTAL PRECIPITATION FOR 2014 = 29.93 inches