

Darboy Sanitary District

2015 Flow Data

DAILY AVERAGE FLOW VOLUME (MGD):	0.92	
PEAK MONTHLY FLOW VOLUME (MGD):	1.05	
PEAK HOURLY FLOW VOLUME (MGD):	3.93	
PEAKING FACTOR RATIO (PEAK MONTHLY:ANNUAL DAILY AVERAGE):		1.14
PEAKING FACTOR RATIO (PEAK HOURLY:ANNUAL DAILY AVERAGE)		4.27

TOTAL PRECIPITATION FOR 2014 = 29.93 inches