

## RESOLUTION NO. 166

Whereas, the Heart of the Valley Metropolitan Sewerage District (District) has a Sewer Use Ordinance which regulates the use of public and private sewers and drains, and the discharge of waters and waste into the public sewerage systems within the District.

Whereas, this Sewer Use Ordinance provides a means for setting limits and standards for discharges from certain users of the sewer systems, through the Districts pretreatment effluent permit system.

Whereas, the stated pH limitations of the individual pretreatment permits issued to users do not match those in the District's Sewer Use Ordinance.

Whereas, the District is requiring that all sewer user pretreatment permits must comply with the Sewer Use Ordinance.

Therefore, be it resolved that all users individual pretreatment permit pH limits be changed to a minimum of 6.0 S.U. and a maximum of 10.5 S.U. to match the Sewer Use Ordinance limitations.

Be it further resolved, that the pH limitation shall be changed in each user's individual pretreatment permit at the time of the permits next renewal.

Adopted, this **12<sup>th</sup> day of May, 2015** by the Commission of the Heart of the Valley Metropolitan Sewerage District.

Approved: \_\_\_\_\_  
David J. Casper, President

Attest: \_\_\_\_\_  
Bruce M. Siebers, Secretary