

HEART OF THE VALLEY - MSD,

ELECTRICAL POWER USE BY MCC

<u>MONTH/YEAR</u>	<u>Headworks Bldg.</u>			<u>Peak Flow Pump Bldg.</u>			<u>Actiflo Bldg.</u>		
	20-MCC-1 <u>KWH</u>	20-MCC-2 <u>KWH</u>	20 - 1+2 <u>KWH</u>	30-MCC-1 <u>KWH</u>	30-MCC-2 <u>KWH</u>	30 - 1+2 <u>KWH</u>	40-MCC-1 <u>KWH</u>	40-MCC-2 <u>KWH</u>	40 - 1+2 <u>KWH</u>
NOV. 2014	19,774	30,387	50,161	5,595	22,180	27,775	49,201	57,946	107,147
DEC. 2014	18,230	33,181	51,411	6,461	25,421	31,882	59,951	58,713	118,664
JAN. 2015	19,020	32,001	51,021	5,670	26,008	31,678	52,353	55,330	107,683
FEB. 2015	14,580	31,028	45,608	4,930	25,123	30,053	45,497	47,900	93,397
MAR. 2015	19,884	32,961	52,845	6,377	22,622	28,999	60,238	50,188	110,426
APR. 2015 ***	24,735	67,589	92,324	64,157	56,306	120,463	134,992	112,223	247,215
MAY. 2015	21,236	32,289	53,525	7,138	21,004	28,142	55,810	64,234	120,044
JUN. 2015	20,150	22,459	42,609	7,719	21,882	29,601	65,320	62,986	128,306
JUL. 2015			0			0			0
AUG. 2015			0			0			0
SEP. 2015			0			0			0
OCT. 2015			0			0			0
NOV. 2015			0			0			0
DEC. 2015			0			0			0

*** Erronious values for April 2015

<u>MONTH/YEAR</u>	<u>Biostyr Blower Bldg.</u>			<u>Solids Bldg.</u>			<u>Electrical / Blower Bldg.</u>		
	50-MCC-1 <u>KWH</u>	50-MCC-2 <u>KWH</u>	50 - 1+2 <u>KWH</u>	60-MCC-1 <u>KWH</u>	60-MCC-2 <u>KWH</u>	60 - 1+2 <u>KWH</u>	70-MCC-1 <u>KWH</u>	70-MCC-2 <u>KWH</u>	70 - 1+2 <u>KWH</u>
NOV. 2014	51,863	100,514	152,377	37,884	25,643	63,527			0
DEC. 2014	54,971	110,275	165,246	42,315	27,080	69,395			0
JAN. 2015	55,550	109,017	164,567	39,841	26,320	66,161			0
FEB. 2015	55,460	92,189	147,649	29,658	27,613	57,271			0
MAR. 2015	60,828	99,162	159,990	33,839	26,553	60,392			0
APR. 2015 ***	62,420	174,621	237,041	76,782	62,916	139,698	13,443		13,443
MAY. 2015	53,434	93,691	147,125	40,000	28,979	68,979	19,048		19,048
JUN. 2015	49,200	91,536	140,736	46,269	75,162	121,431	22,851		22,851
JUL. 2015			0			0			0
AUG. 2015			0			0			0
SEP. 2015			0			0			0
OCT. 2015			0			0			0
NOV. 2015			0			0			0
DEC. 2015			0			0			0

Notes: June - 60 MCC electrical use higher due to running sludge storage pumps for sludge hauling.