Operations Update

<u>Plant Operations</u> – Treatment and operations continue to be doing well for the month of July.

<u>Plant/Kruger SCADA Computers</u> – Due to vacations, installation of the SCADA computers is the week of August 14th. The ATAD programing changes will be accomplished during that time as well.

Maintenance Update

<u>Mitsubishi Air Conditioning ACTI-FLO</u> – At last month's meeting I mentioned the air conditioning went out for the ACTI-FLO MCC room. I received the two quotes; one from EC&D for \$5,840.00, and the other from ACC Planned Service for \$5,016.00. I have ACC Planned Service replacing the unit.

Process Return Pump Drives - Installed last month and are doing great.

<u>Bio-solids storage tank valves</u> – Still in the process of pumping the contents of storage tank 2 into storage tank 1. No update on the valve repair needed or what the floor condition is.

<u>Driveway Seal Coating</u> – Finally had a weekend where there was no rain forecasted and AC Asphalt Specialists were able to come in and seal the driveway/parking lot. This was supposed to be accomplished in 2016 but due to weather it had been postponed until 2017. There was \$17,000 budgeted for this in 2016 due to a quote I received from another company, however AC Asphalt had quoted 8,540.00

<u>Biostyr Blower</u> – There is one blower that had a bearing failure which has been removed and sent into Aerzen for a standard overhaul. The standard overhaul cost is \$4,070.00. If there are more costs associated to it due to items not covered under the normal rebuild, I will determine at that time whether a new blower will be the most economical route. A new blower costs approximately \$8,400.00

Director of Operations and Maintenance Kevin Skogman