

Darboy Sanitary District

2017 Flow Data

DAILY AVERAGE FLOW VOLUME (MGD):	0.94	
PEAK MONTHLY FLOW VOLUME (MGD):	1.11	
PEAK HOURLY FLOW VOLUME (MGD):	2.46	
PEAKING FACTOR RATIO (PEAK MONTHLY:ANNUAL DAILY AVERAGE):		1.18
PEAKING FACTOR RATIO (PEAK HOURLY:ANNUAL DAILY AVERAGE):		2.61
TOTAL PRECIPITATION FOR 2017 =	26.72	