

Operations Update

Plant Operations – Plant operations and treatment were good for the month of February. Pounds limits for suspended solids were met; no credits were used from the Treatment basin.

Maintenance Update

Day Tank Mixer (Wilo mixer) – The motor on the mixer recently went bad and was sent to L & S electric. The quote to have the motor repaired plus to have the planetary gear box rebuilt, new cables installed, is \$8,517. A new mixer quote through Energenecs is \$12,715. My recommendation is to purchase new mixer.

Laser Flow System Meters – Laser flow meter for 5 North has been received and will be installed in the near future.

HOV Agricultural Land (Grass Buffers) – The extension for cost sharing for the rock equipment crossings has been extended from March to July 2019.

ATAD Jet Mix Pump Quotation – Order has been placed for the two ATAD pumps.

Turbine Pump #1 Rebuild – Pump was removed on March 5th-updates to follow after pump is disassembled and all parts are inspected.

Kevin Skogman
Director of Operations & Maintenance