

Village of Combined Locks

2018 Flow Data

DAILY AVERAGE FLOW VOLUME (MGD):	0.35	
PEAK MONTHLY FLOW VOLUME (MGD):	0.54	
PEAK HOURLY FLOW VOLUME (MGD):	3.46	
PEAKING FACTOR RATIO (PEAK MONTHLY:ANNUAL DAILY AVERAGE):		1.54
PEAKING FACTOR RATIO (PEAK HOURLY:ANNUAL DAILY AVERAGE):		9.94
TOTAL PRECIPITATION FOR 2018 =	28.37	