


DISTRICT DIRECTOR:

Brian M. Helminger

SERVING:

Combined Locks
Kaukauna
Kimberly
Little Chute
Darboy S.D.



COMMISSIONERS:

David J. Casper, President
Bruce M. Siebers, Vice-Pres.
Kevin P. Coffey, Secretary
Patrick E. Hennessey
John W. Sundelius

**Heart of the Valley
METROPOLITAN SEWERAGE DISTRICT**

801 THILMANY ROAD
KAUKAUNA, WISCONSIN 54130
(920) 766-5731 FAX (920) 766-5733
www.hvmsd.org

**PUBLIC NOTICE REGARDING LANGUAGE CHANGES TO
THE HEART OF THE VALLEY METROPOLITAN SEWERAGE DISTRICT
SEWER USE ORDINANCE**

Please take notice that a Public Hearing will be held regarding the Sewer Use Ordinance language changes on Tuesday, April 11, 2017 at 6:00 PM at the Heart of the Valley Metropolitan Sewerage District, 801 Thilmany Road, Kaukauna, WI 54130

SEC. 15.04 ADMINISTRATIVE ENFORCEMENT

(4) Administrative Fines

Insert (k) Failure to install, maintain, or adequately service a

Grease and/or Sand trap - \$50/day

.....
ACKNOWLEDGEMENT OF RECEIPT

Received By: _____

Date: _____

3/14/2017

B. FOG Program Update

John Stoeger of Stoeger & Associates provided a written FOG update by community. The Commission also received an itemized copy of the February 2017 invoice. After a discussion, the Commission gave direction to televise areas of concern if necessary, with HOV paying the cost, and also directed staff to notify the community prior to the televising. District Director Helminger noted that he will talk with John Stoeger and have a status report for next month.

A Public Hearing notice regarding a modification to the District's Sewer Use Ordinance was published in the Appleton Post Crescent along with the notice being sent to each community. The Public Hearing will take place on April 11, 2017. The modification consists of adding language under Sec. 15.04 Administrative Enforcement; (4)(k) Failure to install, maintain, or adequately service a grease and/or sand trap - \$50 / day.

C. Chemical Use Report for 2016

Kevin Skogman, Director of Operations & Maintenance, provided a written update showing the chemical use for 2016, along with gas, electric, and water consumption. The report also detailed the cost of the chemical purchase, gallons purchased, and cost per MGD treated.

D. Equipment Automation & Efficiencies

District Director Helminger updated the commission on the status of the SCADA system upgrade. Staff is also investigating a potential electrical savings by making an operational change to process waste biosolids to the ATAD late in the day, to take advantage of off peak hours energy costs.

PLANT REPORTS:

1. 2017 Flows & Revenues Report / Plant Operation Summary

The Commission received a copy of the Flow & Strength charts, which shows the year to date surplus/deficit revenue for the month of February. Revenue received from WPS/Fox Energy Center for final effluent purchased in February = \$9,302.61. Total revenue received to date from Fox Energy for 2017 = \$19,531.48.

The average final effluent concentrations for **February 2017** were as follows:

cBOD	5.25 mg/l
Suspended Solids	8.77 mg/l
Phosphorus	.22 mg/l
Ammonia-N	.26 mg/l
Chlorides	556.67 mg/l

**** All permit values were met for February 2017 ****