

Operations Update

Plant Operations – Plant operations and treatment were good for the month of February. No TSS credits were used from the Water Quality Trading Plan.

Bio-Solids Hauling – No hauling due to winter. United Liquid Waste has been in contact; if there is a window of opportunity to inject bio-solids in the spring I may have about 50 acres that can be injected on.

Process Control Technician – The plant is in the process of hiring a PCT/Operator due to a retirement last month. We received resumes from several highly qualified candidates and are currently in the process of interviewing.

Maintenance Update

Biostyr Blower – Have been in the process of getting quotes for the replacement of the blower that had caught fire last month. As of this writing there were two quotes yet to come in. When received I will be sending all estimates in to the insurance company.

Post ATAD Blower – Recently had one of the three blowers for Post ATAD 1 & 2 fail. The blower has been sent to Aerzen for a standard overhaul. The cost for the standard overhaul is \$4,280.00.

Post ATAD 1 & 2 Jet Pumps – Rotating assemblies have been received and installed.

Main Gate Operator – The gate operator has been ordered.

HOV Agricultural Land (Grass Buffers) – No update.

Kevin Skogman
Director of Operations & Maintenance