

Darboy Sanitary District

2019 Flow Data

DAILY AVERAGE FLOW VOLUME (MGD):	0.98	
PEAK MONTHLY FLOW VOLUME (MGD):	1.09	
PEAK HOURLY FLOW VOLUME (MGD):	3.51	
PEAKING FACTOR RATIO (PEAK MONTHLY:ANNUAL DAILY AVERAGE):		1.12
PEAKING FACTOR RATIO (PEAK HOURLY:ANNUAL DAILY AVERAGE):		3.59

TOTAL PRECIPITATION FOR 2019* = 29.45

*April-October