

## **Operations Update**

Plant Operations – Plant operations and treatment were for the most part good during the month of May. However, the plant had high flows on May 17<sup>th</sup> and 18<sup>th</sup>. There was no blending during this event but final effluent solids were high. This event caused the plant to use water quality trading credits. On May 28<sup>th</sup> the plant again had high flows due to rain. There was a blending event during this rainfall but treatment remained stable and no water quality trading credits were needed for the weekly average.

The water quality trading (TSS lbs/yr) credits that HOV has for 2020 is 2756. The calculated credits needed for the week of the 17<sup>th</sup> was 5705. This single event depletes all of the District's TSS credits for 2020.

Bio-Solids Hauling – United Liquid Waste has hauled out 1.6 million gallons of bio-solids.

## **Maintenance Update**

PLC Upgrades at Meter Stations – As soon as LW Allen receives all the parts needed to do the upgrade they will be scheduling to come in.

Biostyr Blower – The blower's projected delivery is the beginning of July.

Final Effluent Reuse Pump – The new reuse pump has been ordered.

HOV Agricultural Land (Grass Buffers) – No update.

Kevin Skogman  
Director of Operations & Maintenance