

Operations Update

Plant Operations – Plant operations and treatment were good during the month of July.

Bio-Solids Hauling – United Liquid Waste finished hauling bio-solids on July 25th. There was 2.95 million gallons hauled. With what was hauled in May, the total for the year was 4.53 million gallons.

Maintenance Update

ATAD/Peak Flow Pump Drives – The VFD's have been removed and sent off to Werner Electric for rebuild. It will be 1-2 weeks for the ATAD drive and 2-4 weeks for the peak flow pump drive to be rebuilt.

ATAD Digester – Bio-solids storage tanks are emptied. The plant is scheduled to have a much needed cleaning of the ATAD digester the last week of August.

PLC Upgrades at Meter Stations – Upgrades to the PLC and SCADA system is scheduled for the first part of October due to LW Allen's programmers are behind schedule because of the Covid-19 pandemic.

Biostyr Blower – The blower has been received and Sabel Mechanical will be in on August 10th to start installing.

Final Effluent Reuse Pump – The new reuse pump has been ordered.

HOV Agricultural Land (Grass Buffers) – No update.

Kevin Skogman
Director of Operations & Maintenance