

Operations Update

Plant Operations – Plant operations and treatment were good during the month of August.

Maintenance Update

34" siphon – Great Lakes TV & Seal cleaned the 34" siphon in August, gate was put in place in manhole 42 to route all normal flows to the 16" siphon while permanent weir for operations of siphon was being fabricated. Weir has been received and installed.

ATAD/Peak Flow Pump Drives – The VFD's have been repaired, installed, and are back on line.

ATAD Digester – Digester was cleaned the last week of August, put back into service, and is back up to operating temperature.

PLC Upgrades at Meter Stations – Upgrades to the PLC and SCADA system is scheduled for the first part of October due to LW Allen's programmers being behind schedule because of the Covid-19 pandemic.

Biostyr Blower – The blower was installed by Sabel Mechanical and the electrical work has been completed by Elm-Star Electric. Insulation of piping is scheduled and when completed the blower will be back in full operation.

Final Effluent Reuse Pump – The reuse pump has been received and installed and we are currently waiting for the motor to come back from being refurbished.

HOV Agricultural Land (Grass Buffers) – No update.

Kevin Skogman
Director of Operations & Maintenance