

Operations Update

Plant Operations – Plant operations and treatment were good during the month of January.

Maintenance Update

Laser Flow Meter Modems – Received the Flow-link Pro Software and modems to connect with the laser flow meters. When the micro SIM cards are received for the modems, Mulcahy Shaw will assist in startup. (2/3/2021) waiting on micro SIM cards.

Headworks Heating/Ventilation Unit – Received proper size drive and installed. The drive that was temporary on the HV unit installed where it was intended to go.

ATAD Digester – Last month I mentioned that the plant was in the process of draining the digester due to a blockage in the air header causing excessive back pressure on the blower. Found the cause to be scale (1/4" to 3/8") that had coated the pipe from several years ago, had broken loose, shattered and plugged the air nozzles. Flush Drain & Sewer came in and jetted out the air header to the point of where the scale originated. HOV employees then cleaned out the air nozzles and ATAD was back on line and filling in about three days.

Kevin Skogman
Director of Operations & Maintenance