

**Wastewater Discharge Monitoring Long Report**

**For DNR Use Only**

Facility Name: HEART OF THE VALLEY METRO SEWERAGE DISTRICT  
 Contact Address: 801 Thilmany Rd  
 Kaukauna, WI 54130  
 Facility Contact: Brian Helming, District Director  
 Phone Number: 920-766-5731  
 Reporting Period: 10/01/2021 - 10/31/2021  
 Form Due Date: 11/21/2021  
 Permit Number: 0031232

Date Received:  
 DOC: 479880  
 FIN: 6375  
 FID: 445005220  
 Region: Northeast Region  
 Permit Drafter: Drafter not set  
 Reviewer: Barti Oumarou  
 Office: Oshkosh

	Sample Point	001	701	701	701	701
	Description	Effluent	Influent	Influent	Influent	Influent
	Parameter	211	211	66	457	87
	Description	Flow Rate	Flow Rate	BOD5, Total	Suspended Solids, Total	Cadmium, Total Recoverable
	Units	MGD	MGD	mg/L	mg/L	ug/L
	Sample Type	CONTINUOUS	CONTINUOUS	24 HR FLOW PROP	24 HR FLOW PROP	24 HR FLOW PROP
	Frequency	DAILY	DAILY	5/WEEK	5/WEEK	MONTHLY
Sample Results	Day 1	5.370	5.370	303	244	
	2	5.464	5.464	302	236	
	3	6.212	6.212	291	244	
	4	5.529	5.529	293	232	
	5	5.484	5.484	312	228	<1.3
	6	5.622	5.622	275	268	
	7	5.831	5.831	350	264	
	8	6.038	6.038	282	164	
	9	5.512	5.543	269	176	
	10	4.535	6.209	269	192	
	11	3.592	5.990	306	236	
	12	3.999	6.181	265	232	
	13	3.552	5.902	294	240	
	14	3.878	5.966	339	232	
	15	3.166	5.504	350	208	
	16	2.837	5.409	304	208	
	17	2.800	5.604	273	216	
	18	1.984	5.353	303	224	
	19	20.31	5.457	302	244	
	20	2.231	5.317	386	240	
	21	1.990	5.257	380	264	
	22	2.229	5.314	384	224	
	23	1.970	5.004	377	212	
	24	2.284	5.385	295	276	
	25	1.962	5.017	302	244	
	26	2.127	5.059	319	264	
	27	1.571	4.971	404	316	
	28	2.124	5.078	268	264	
	29	2.228	5.045	327	184	
	30	1.541	4.947	313	212	
	31	2.709	5.429	335	256	

	Sample Point	001	701	701	701	701
	Description	Effluent	Influent	Influent	Influent	Influent
	Parameter	211	211	66	457	87
	Description	Flow Rate	Flow Rate	BOD5, Total	Suspended Solids, Total	Cadmium, Total Recoverable
	Units	MGD	MGD	mg/L	mg/L	ug/L
<b>Summary Values</b>	<b>Monthly Avg</b>	4.086483871	5.499709677	315.225806452	233.677419355	0
	<b>Daily Max</b>	20.31	6.212	404	316	<1.3
	<b>Daily Max - Variable</b>					
	<b>Daily Min</b>	1.541	4.947	265	164	<1.3
	<b>Week 1 Avg</b>					
	<b>Week 2 Avg</b>					
	<b>Week 3 Avg</b>					
	<b>Week 4 Avg</b>					
<b>Limit(s) in Effect</b>	<b>Monthly Avg</b>					
	<b>Daily Max</b>					
	<b>Daily Max - Variable</b>					
	<b>Daily Min</b>					
	<b>Weekly Avg</b>					
<b>QA/QC Information</b>	<b>LOD</b>					1.3
	<b>LOQ</b>					5
	<b>QC Exceedance</b>	N	N	Y	N	N
	<b>Lab Certification</b>			445005220	445005220	405132750

	<b>Sample Point</b>	701	001	701	701	701
	<b>Description</b>	Influent	Effluent	Influent	Influent	Influent
	<b>Parameter</b>	133	66	147	264	315
	<b>Description</b>	Chromium, Total Recoverable	BOD5, Total	Copper, Total Recoverable	Lead, Total Recoverable	Nickel, Total Recoverable
	<b>Units</b>	ug/L	mg/L	ug/L	ug/L	ug/L
	<b>Sample Type</b>	24 HR FLOW PROP	24 HR FLOW PROP	24 HR FLOW PROP	24 HR FLOW PROP	24 HR FLOW PROP
	<b>Frequency</b>	MONTHLY	DAILY	MONTHLY	MONTHLY	MONTHLY
<b>Sample Results</b>	<b>Day 1</b>		7			
	<b>2</b>		9			
	<b>3</b>		14			
	<b>4</b>		11			
	<b>5</b>	11.6	12	65.8	10.9	8.2
	<b>6</b>		8			
	<b>7</b>		10			
	<b>8</b>		9			
	<b>9</b>		11			
	<b>10</b>		10			
	<b>11</b>		9			
	<b>12</b>		10			
	<b>13</b>		15			
	<b>14</b>		13			
	<b>15</b>		13			
	<b>16</b>		9			
	<b>17</b>		15			
	<b>18</b>		16			
	<b>19</b>		10			
	<b>20</b>		14			
	<b>21</b>		20			
	<b>22</b>		13			
	<b>23</b>		15			
	<b>24</b>		17			
	<b>25</b>		18			
	<b>26</b>		13			
	<b>27</b>		9			
	<b>28</b>		11			
	<b>29</b>		12			
	<b>30</b>		16			
	<b>31</b>		14			

	<b>Sample Point</b>	701	001	701	701	701
	<b>Description</b>	Influent	Effluent	Influent	Influent	Influent
	<b>Parameter</b>	133	66	147	264	315
	<b>Description</b>	Chromium, Total Recoverable	BOD5, Total	Copper, Total Recoverable	Lead, Total Recoverable	Nickel, Total Recoverable
	<b>Units</b>	ug/L	mg/L	ug/L	ug/L	ug/L
<b>Summary Values</b>	<b>Monthly Avg</b>	11.6	12.35483871	65.8	10.9	8.2
	<b>Daily Max</b>	11.6	20	65.8	10.9	8.2
	<b>Daily Max - Variable</b>					
	<b>Daily Min</b>	11.6	7	65.8	10.9	8.2
	<b>Week 1 Avg</b>		10.142857143			
	<b>Week 2 Avg</b>		11			
	<b>Week 3 Avg</b>		13.857142857			
	<b>Week 4 Avg</b>		13.714285714			
<b>Limit(s) in Effect</b>	<b>Monthly Avg</b>		30	0		
	<b>Daily Max</b>					
	<b>Daily Max - Variable</b>					
	<b>Daily Min</b>					
	<b>Weekly Avg</b>		45	0		
<b>QA/QC Information</b>	<b>LOD</b>	2.5		3.4	5.9	2.6
	<b>LOQ</b>	10		10	20	10
	<b>QC Exceedance</b>	N	N	N	N	N
	<b>Lab Certification</b>	405132750	445005220	405132750	405132750	405132750

	<b>Sample Point</b>	701	001	001	001	001
	<b>Description</b>	Influent	Effluent	Effluent	Effluent	Effluent
	<b>Parameter</b>	553	377	457	457	1348
	<b>Description</b>	Zinc, Total Recoverable	pH Field	Suspended Solids, Total	Suspended Solids, Total	WQT Credits Used (TSS)
	<b>Units</b>	ug/L	su	mg/L	lbs/day	lbs/month
	<b>Sample Type</b>	24 HR FLOW PROP	GRAB	24 HR FLOW PROP	CALCULATED	CALCULATED
	<b>Frequency</b>	MONTHLY	5/WEEK	5/WEEK	5/WEEK	MONTHLY
<b>Sample Results</b>	<b>Day 1</b>		7.2	13.2	591	0
	<b>2</b>		7.4	14.0	638	0
	<b>3</b>		7.5	15.2	787	0
	<b>4</b>		7.5	14.0	646	0
	<b>5</b>	155	7.1	15.6	713	0
	<b>6</b>		7.1	12.8	600	0
	<b>7</b>		7.1	13.2	642	0
	<b>8</b>		7.4	13.2	665	0
	<b>9</b>		7.8	14.0	644	0
	<b>10</b>		8.0	16.8	635	0
	<b>11</b>		7.4	23.2	595	0
	<b>12</b>		7.4	19.6	654	0
	<b>13</b>		7.2	19.2	569	0
	<b>14</b>		7.1	18.0	582	0
	<b>15</b>		7.1	18.4	486	0
	<b>16</b>		7.5	14.0	331	0
	<b>17</b>		7.5	23.2	542	0
	<b>18</b>		7.4	20.4	338	0
	<b>19</b>		7.2	12.8	217	0
	<b>20</b>		7.2	18.4	342	0
	<b>21</b>		7.3	17.2	285	0
	<b>22</b>		7.3	19.6	364	0
	<b>23</b>		7.4	22.0	361	0
	<b>24</b>		7.4	20.0	381	0
	<b>25</b>		7.2	22.8	373	0
	<b>26</b>		7.3	18.4	326	0
	<b>27</b>		7.3	15.6	204	0
	<b>28</b>		7.2	14.0	248	0
	<b>29</b>		7.3	17.2	320	0
	<b>30</b>		7.3	14.0	180	0
	<b>31</b>		7.3	16.0	361	0

	Sample Point	701	001	001	001	001
	Description	Influent	Effluent	Effluent	Effluent	Effluent
	Parameter	553	377	457	457	1348
	Description	Zinc, Total Recoverable	pH Field	Suspended Solids, Total	Suspended Solids, Total	WQT Credits Used (TSS)
Units	ug/L	su	mg/L	lbs/day	lbs/month	
<b>Summary Values</b>	<b>Monthly Avg</b>	155	7.335483871	16.967741935	471.612903226	0
	<b>Daily Max</b>	155	8	23.2	787	0
	<b>Daily Max - Variable</b>					
	<b>Daily Min</b>	155	7.1	12.8	180	0
	<b>Week 1 Avg</b>			14		
	<b>Week 2 Avg</b>			17.714285714		
	<b>Week 3 Avg</b>			17.771428571		
	<b>Week 4 Avg</b>			18.914285714		
<b>Limit(s) in Effect</b>	<b>Monthly Avg</b>			30	0	
	<b>Daily Max</b>		9	0		
	<b>Daily Max - Variable</b>					
	<b>Daily Min</b>		6	0		
	<b>Weekly Avg</b>			45	0	
<b>QA/QC Information</b>	<b>LOD</b>	11.6				
	<b>LOQ</b>	40				
	<b>QC Exceedance</b>	N	N	N	N	N
	<b>Lab Certification</b>	405132750		445005220		

	<b>Sample Point</b>	001	001	001	001	001
	<b>Description</b>	Effluent	Effluent	Effluent	Effluent	Effluent
	<b>Parameter</b>	1347	388	388	789	87
	<b>Description</b>	WQT Computed Compliance (TSS)	Phosphorus, Total	Phosphorus, Total	Nitrogen, Ammonia (NH3-N) Total	Cadmium, Total Recoverable
	<b>Units</b>	lbs/day	mg/L	lbs/day	mg/L	ug/L
	<b>Sample Type</b>	CALCULATED	24 HR FLOW PROP	CALCULATED	24 HR FLOW PROP	24 HR FLOW PROP
	<b>Frequency</b>	5/WEEK	5/WEEK	5/WEEK	5/WEEK	MONTHLY
<b>Sample Results</b>	<b>Day 1</b>	591	0.32	14.33		
	<b>2</b>	638	0.34	15.49		
	<b>3</b>	787	0.49	25.39	0.7	
	<b>4</b>	646	0.35	16.14	0.4	
	<b>5</b>	713	0.40	18.29	0.5	<1.3
	<b>6</b>	600	0.35	16.41	0.3	
	<b>7</b>	642	0.38	18.48	0.4	
	<b>8</b>	665	0.35	17.62		
	<b>9</b>	644	0.33	15.17		
	<b>10</b>	635	0.42	15.89	0.4	
	<b>11</b>	695	0.95	28.46	0.8	
	<b>12</b>	654	0.33	11.01	0.4	
	<b>13</b>	569	0.35	10.37	0.4	
	<b>14</b>	582	0.41	13.26	0.4	
	<b>15</b>	486	0.39	10.30		
	<b>16</b>	331	0.37	8.75		
	<b>17</b>	542	0.45	10.51	0.5	
	<b>18</b>	338	0.40	6.62	0.7	
	<b>19</b>	217	0.33	5.59	0.7	
	<b>20</b>	342	0.35	6.51	0.6	
	<b>21</b>	285	0.43	7.14	1.0	
	<b>22</b>	364	0.48	8.92		
	<b>23</b>	361	0.44	7.23		
	<b>24</b>	381	0.48	9.14	0.7	
	<b>25</b>	373	0.53	8.67	0.4	
	<b>26</b>	326	0.37	6.56	0.3	
	<b>27</b>	204	0.29	3.80	0.3	
	<b>28</b>	248	0.40	7.09	0.4	
	<b>29</b>	320	0.28	5.20		
	<b>30</b>	180	0.41	5.27		
	<b>31</b>	361	0.41	9.26	0.6	

	<b>Sample Point</b>	001		001		001		001		001	
	<b>Description</b>	Effluent		Effluent		Effluent		Effluent		Effluent	
	<b>Parameter</b>	1347		388		388		789		87	
	<b>Description</b>	WQT Computed Compliance (TSS)		Phosphorus, Total		Phosphorus, Total		Nitrogen, Ammonia (NH3-N) Total		Cadmium, Total Recoverable	
	<b>Units</b>	lbs/day		mg/L		lbs/day		mg/L		ug/L	
<b>Summary Values</b>	<b>Monthly Avg</b>	474.838709677		0.405806452		11.705483871		0.519047619		0	
	<b>Daily Max</b>	787		0.95		28.46		1		<1.3	
	<b>Daily Max - Variable</b>										
	<b>Daily Min</b>	180		0.28		3.8		0.3		<1.3	
	<b>Week 1 Avg</b>	659.571428571						0.46			
	<b>Week 2 Avg</b>	634.857142857						0.48			
	<b>Week 3 Avg</b>	363						0.7			
	<b>Week 4 Avg</b>	322.428571429						0.42			
<b>Limit(s) in Effect</b>	<b>Monthly Avg</b>	801	0	1	0			18	0		
	<b>Daily Max</b>							17	0		
	<b>Daily Max - Variable</b>										
	<b>Daily Min</b>										
	<b>Weekly Avg</b>	1345	0					17	0		
<b>QA/QC Information</b>	<b>LOD</b>			0.026				0.027		1.3	
	<b>LOQ</b>			0.087				0.09		5	
	<b>QC Exceedance</b>	N		N		N		N		N	
	<b>Lab Certification</b>			445005220				445005220		405132750	

	<b>Sample Point</b>	001	001	001	001	001
	<b>Description</b>	Effluent	Effluent	Effluent	Effluent	Effluent
	<b>Parameter</b>	133	147	264	315	553
	<b>Description</b>	Chromium, Total Recoverable	Copper, Total Recoverable	Lead, Total Recoverable	Nickel, Total Recoverable	Zinc, Total Recoverable
	<b>Units</b>	ug/L	ug/L	ug/L	ug/L	ug/L
	<b>Sample Type</b>	24 HR FLOW PROP	24 HR FLOW PROP	24 HR FLOW PROP	24 HR FLOW PROP	24 HR FLOW PROP
	<b>Frequency</b>	MONTHLY	MONTHLY	MONTHLY	MONTHLY	MONTHLY
<b>Sample Results</b>	<b>Day 1</b>					
	<b>2</b>					
	<b>3</b>					
	<b>4</b>					
	<b>5</b>	2.8	6.9	<5.9	7.5	19.2
	<b>6</b>					
	<b>7</b>					
	<b>8</b>					
	<b>9</b>					
	<b>10</b>					
	<b>11</b>					
	<b>12</b>					
	<b>13</b>					
	<b>14</b>					
	<b>15</b>					
	<b>16</b>					
	<b>17</b>					
	<b>18</b>					
	<b>19</b>					
	<b>20</b>					
	<b>21</b>					
	<b>22</b>					
	<b>23</b>					
	<b>24</b>					
	<b>25</b>					
	<b>26</b>					
	<b>27</b>					
	<b>28</b>					
	<b>29</b>					
	<b>30</b>					
	<b>31</b>					

	<b>Sample Point</b>	001	001	001	001	001
	<b>Description</b>	Effluent	Effluent	Effluent	Effluent	Effluent
	<b>Parameter</b>	133	147	264	315	553
	<b>Description</b>	Chromium, Total Recoverable	Copper, Total Recoverable	Lead, Total Recoverable	Nickel, Total Recoverable	Zinc, Total Recoverable
	<b>Units</b>	ug/L	ug/L	ug/L	ug/L	ug/L
<b>Summary Values</b>	<b>Monthly Avg</b>	2.8	6.9	0	7.5	19.2
	<b>Daily Max</b>	2.8	6.9	<5.9	7.5	19.2
	<b>Daily Max - Variable</b>					
	<b>Daily Min</b>	2.8	6.9	<5.9	7.5	19.2
	<b>Week 1 Avg</b>					
	<b>Week 2 Avg</b>					
	<b>Week 3 Avg</b>					
	<b>Week 4 Avg</b>					
<b>Limit(s) in Effect</b>	<b>Monthly Avg</b>					
	<b>Daily Max</b>					
	<b>Daily Max - Variable</b>					
	<b>Daily Min</b>					
	<b>Weekly Avg</b>					
<b>QA/QC Information</b>	<b>LOD</b>	1.3	3.4	5.9	2.6	11.6
	<b>LOQ</b>	5	10	20	10	40
	<b>QC Exceedance</b>	N	N	N	N	N
	<b>Lab Certification</b>	405132750	405132750	405132750	405132750	405132750

	<b>Sample Point</b>	101	601	601	601	006
	<b>Description</b>	Effluent Reuse	River Monitoring	River Monitoring	River Monitoring	WLA BOD5 Discharge Compliance
	<b>Parameter</b>	671	400	399	401	544
	<b>Description</b>	Flow Unregulated	WLA Previous Day River Flow	WLA Previous 4 Day Avg River Flow	WLA Previous Day River Temp	WLA BOD5 Value
	<b>Units</b>	MGD	cfs	cfs	degF	lbs/day
	<b>Sample Type</b>	CONTINUOUS	GAUGE STN	CALCULATED	CALCULATED	SEE TABLE
	<b>Frequency</b>	DAILY	DAILY	DAILY	DAILY	DAILY
<b>Sample Results</b>	<b>Day 1</b>	0	3520	3648	66	2995
	<b>2</b>	0	3560	3585	67	2995
	<b>3</b>	0	3610	3560	69	2995
	<b>4</b>	0	3700	3560	69	2995
	<b>5</b>	0	4160	3598	69	2995
	<b>6</b>	0	4380	3758	67	2995
	<b>7</b>	0	4410	3963	67	3515
	<b>8</b>	0	4380	4163	67	3515
	<b>9</b>	0.031	4400	4333	67	3515
	<b>10</b>	1.674	4510	4393	67	3515
	<b>11</b>	2.398	4510	4425	67	3515
	<b>12</b>	2.182	5510	4450	67	3515
	<b>13</b>	2.350	6230	4733	66	5323
	<b>14</b>	2.088	6200	5190	66	5568
	<b>15</b>	2.338	5180	5613	65	5568
	<b>16</b>	2.572	5070	5780	64	5568
	<b>17</b>	2.804	5030	5670	61	5568
	<b>18</b>	3.369	4890	5370	60	5568
	<b>19</b>	3.426	4780	5043	59	5568
	<b>20</b>	3.086	4740	4943	60	4995
	<b>21</b>	32.67	4990	4860	60	4995
	<b>22</b>	3.085	4860	4850	60	4995
	<b>23</b>	3.034	4570	4843	57	5568
	<b>24</b>	3.101	4490	4790	56	5568
	<b>25</b>	3.055	3840	4728	55	5568
	<b>26</b>	2.932	2610	4440	53	5568
	<b>27</b>	3.400	2480	3878	52	5568
	<b>28</b>	2.954	2520	3355	52	5568
	<b>29</b>	2.817	2700	2863	53	4857
	<b>30</b>	3.406	2630	2578	52	4367
	<b>31</b>	2.720	2450	2583	52	4367

	Sample Point	101	601	601	601	006
	Description	Effluent Reuse	River Monitoring	River Monitoring	River Monitoring	WLA BOD5 Discharge Compliance
	Parameter	671	400	399	401	544
	Description	Flow Unregulated	WLA Previous Day River Flow	WLA Previous 4 Day Avg River Flow	WLA Previous Day River Temp	WLA BOD5 Value
	Units	MGD	cfs	cfs	degF	lbs/day
<b>Summary Values</b>	<b>Monthly Avg</b>	2.951354839	4222.903225806	4307.935483871	61.677419355	4508.870967742
	<b>Daily Max</b>	32.67	6230	5780	69	5568
	<b>Daily Max - Variable</b>					
	<b>Daily Min</b>	0	2450	2578	52	2995
	<b>Week 1 Avg</b>					
	<b>Week 2 Avg</b>					
	<b>Week 3 Avg</b>					
	<b>Week 4 Avg</b>					
<b>Limit(s) in Effect</b>	<b>Monthly Avg</b>					
	<b>Daily Max</b>					
	<b>Daily Max - Variable</b>					
	<b>Daily Min</b>					
	<b>Weekly Avg</b>					
<b>QA/QC Information</b>	<b>LOD</b>					
	<b>LOQ</b>					
	<b>QC Exceedance</b>	N	N	N	N	N
	<b>Lab Certification</b>					

	Sample Point	006	006	006	006	112
	Description	WLA BOD5 Discharge Compliance	WLA BOD5 Discharge Compliance	WLA BOD5 Discharge Compliance	WLA BOD5 Discharge Compliance	In-Plant Diversion
	Parameter	12	843	543	541	211
	Description	WLA Adjusted Value	WLA BOD5 Discharged	WLA 7 Day Sum Of WLA Values	WLA 7 Day Sum Of BOD5 Discharged	Flow Rate
	Units	lbs/day	lbs/day	lbs/day	lbs/day	MGD
	Sample Type	CALCULATED	CALCULATED	CALCULATED	CALCULATED	CONTINUOUS
	Frequency	DAILY	DAILY	DAILY	DAILY	DAILY
<b>Sample Results</b>	<b>Day 1</b>	4133	316	24951	2959	0
	<b>2</b>	4133	393	24893	3018	0
	<b>3</b>	4133	705	23780	3197	0
	<b>4</b>	4133	521	22667	3157	0
	<b>5</b>	4133	558	21554	3258	0
	<b>6</b>	4133	382	21023	3241	0
	<b>7</b>	4851	501	20965	3375	0
	<b>8</b>	4851	473	21485	3533	0
	<b>9</b>	4851	510	22005	3650	0
	<b>10</b>	4851	361	22525	3306	0
	<b>11</b>	4851	255	23045	3040	0
	<b>12</b>	4851	337	23565	2819	0
	<b>13</b>	7346	435	24085	2873	0
	<b>14</b>	7684	420	26413	2793	0
	<b>15</b>	7684	333	28466	2652	0
	<b>16</b>	7684	219	30519	2360	0
	<b>17</b>	7684	350	32572	2349	0
	<b>18</b>	7684	261	34625	2356	0
	<b>19</b>	7684	166	36678	2185	0
	<b>20</b>	6893	255	38158	2005	0
	<b>21</b>	6893	325	37830	1909	0
	<b>22</b>	6893	232	37257	1809	0
	<b>23</b>	7684	242	37257	1832	0
	<b>24</b>	7684	320	37257	1802	0
	<b>25</b>	7684	290	37257	1830	0
	<b>26</b>	7684	238	37257	1901	0
	<b>27</b>	7684	124	37830	1771	0
	<b>28</b>	7684	190	38403	1635	0
	<b>29</b>	6703	219	38265	1622	0
	<b>30</b>	6026	200	37064	1581	0
	<b>31</b>	6026	310	35863	1570	0

	Sample Point	006	006	006	006	112
	Description	WLA BOD5 Discharge Compliance	WLA BOD5 Discharge Compliance	WLA BOD5 Discharge Compliance	WLA BOD5 Discharge Compliance	In-Plant Diversion
	Parameter	12	843	543	541	211
	Description	WLA Adjusted Value	WLA BOD5 Discharged	WLA 7 Day Sum Of WLA Values	WLA 7 Day Sum Of BOD5 Discharged	Flow Rate
	Units	lbs/day	lbs/day	lbs/day	lbs/day	MGD
<b>Summary Values</b>	<b>Monthly Avg</b>	6222.322580645	336.806451613	30177.870967742	2496.387096774	0
	<b>Daily Max</b>	7684	705	38403	3650	0
	<b>Daily Max - Variable</b>		705		3650	
	<b>Daily Min</b>	4133	124	20965	1570	0
	<b>Week 1 Avg</b>					
	<b>Week 2 Avg</b>					
	<b>Week 3 Avg</b>					
	<b>Week 4 Avg</b>					
<b>Limit(s) in Effect</b>	<b>Monthly Avg</b>					
	<b>Daily Max</b>					
	<b>Daily Max - Variable</b>		0	0	0	0
	<b>Daily Min</b>					
	<b>Weekly Avg</b>					
<b>QA/QC Information</b>	<b>LOD</b>					
	<b>LOQ</b>					
	<b>QC Exceedance</b>	N	N	N	N	N
	<b>Lab Certification</b>					

Footnotes (DNR Use Only; Instructions for completing this form that are unique for your facility may be displayed here.)

General Remarks

I certify that management practices identified in the approved water quality trading plan as the source of pollutant reduction credits are installed, established and properly maintained.

Laboratory Quality Control Comments

BOD Blank Exceedance: 10-3-21 (0.25) 10-30-21 (0.25)

Submitted by K3vin1 on 11/11/2021 12:35:38 PM