

## **Operations Update**

Plant Operations – A couple of high flow events in March caused the suspended solids pounds to increase during these events. The plant exceeded the monthly Total Daily Mass Loadings average resulting in the use of 321 Water Quality Trading credits.

Phosphorus Analyzer (Biostyr Effluent) – Analyzer connection to SCADA and to HACH WIMs completed by LW Allen.

## **Maintenance Update**

ATAD Jet Mix Pumps – Rotating assemblies on order.

ATAD Blower #3 – The exchange blower is in the hub and we should be receiving it within the next two weeks.

Air handling unit VFD drive for ACTI-Flo – The drive was remanufactured and returned, installed, & programed and is now back in service.

Sodium Hypochlorite tank repair – Tank has been repaired and leak tested; sodium hypochlorite is on order. May 1<sup>st</sup> begins the disinfection season.

Kevin Skogman  
Director of Operations & Maintenance