

Operations Update

Plant Operations – Plant operations and treatment were good during the month of May.

Ethernet to Device net Module- Recently had an EN to DN module go bad on an MCC. The unit has been replaced and another has been ordered. The wait time is still six months or more to receive.

Maintenance Update

ATAD Jet Mix Pumps – Rotating assemblies were received but with no impellers. Contacted Thermal Process Systems and after some discussion the impellers are supposed to come with the rotating assemblies. Also, there are side plates that were ordered that TPS is trying to find out a ship date.

Peak Flow Pump #3 VFD – The VFD was sent in for the economy rebuild and should be returned within the next 2-4 weeks.

DAFT Pressure Vessel Tanks – The pressure vessels are on order.

Kevin Skogman
Director of Operations & Maintenance