

Operations Update

Plant Operations – Plant operations and treatment were good during the month of September.

Seven Oaks Land Rental – No update.

Maintenance Update

Peak Flow Pump #3 VFD – Updated delivery date of 10/18; subject to change.

DAFT Pressure Vessel Tanks – Received pressure vessels on 10/4.

Heating/Air Conditioning Unit Solids Building Garage – New unit on order; about a 6-month lead time.

ATAD Digester Cleaning – Cleaned ATAD the last week of September. After an inspection we found some patches that were made from header modifications in the past starting to fail. Was able to get Fiber Glass Solutions in to do repairs to the headers. Repairs were made and the ATAD was back in service with very little down time.

Chlorination Season – This ended on September 30th and the cleaning of the contact tank was completed the first week of October.

Kevin Skogman
Director of Operations & Maintenance