

Operations Update

Plant Operations – Plant operations and treatment were good during the month of October.

Seven Oaks Land Rental – In progress.

Maintenance Update

Peak Flow Pump #3 VFD – Updated delivery date of 11/16; subject to change.

DAFT Pressure Vessel Tanks – One pressure vessel has been installed and is ready for startup.

Heating/Air Conditioning Unit Solids Building Garage – New unit on order.

Patterson Kelly Hot Water Boiler – The boiler's micro controller board failed. Board replacement consists of a new board, gas valves, wire harness, & low water cut-out. Cost is \$9,140.00 to repair. Have received two quotes for replacement: 1) Energy Control & Design - \$37,910.00 2) August Winters – \$38,925.00.

Both companies have said that the life of this PK boiler is around twenty years. Looking for authorization to move forward with replacement of boiler with EC&D for \$37,910.00.

Kevin Skogman
Director of Operations & Maintenance