

Operations Update

Plant Operations – Plant operations and treatment were good during the month of January.

Process Control Technician – The job posting is out on the WWOA, Central States and Rural Water websites.

Seven Oaks Land Rental – Changes have been applied to the rental agreement reviewed by HOV legal counsel and is now being reviewed by Seven Oaks.

Maintenance Update

Admin Building AHU Chilled Water Coil – While preventative maintenance on the air handling unit was being performed it was noticed that the coil was leaking. In the process of getting quotes for a new coil.

Bio-Filter (ATAD odor control) – The wood material has been removed and there will be 4 loads of new aggregate arriving the week of February 13th. Had received a quote from R-Industries and August Winters to remove the wood material and add new aggregate. Went with R-Industries because their proposal was less.

Peak Flow Pump #3 VFD – Still waiting on fuses.

Heating/Air Conditioning Unit Solids Building Garage – New unit on order.

P K Boiler – Boiler on order.

Kevin Skogman
Director of Operations & Maintenance