

## **Operations Update**

Plant Operations – Plant operations and treatment were good during the month of February.

Process Control Technician – Still advertising the position.

Seven Oaks Land Rental – Land rental contract is complete.

## **Maintenance Update**

Admin Building AHU Chilled Water Coil – New coil is on order; Energy Control & Design quote \$8,485 and Air Distributors Company \$6,602. Went with Air Distributors, lead time is approximately five weeks.

Bio-Filter (ATAD odor control) – All aggregate was received and put into the bio-filter, discharge pressure now below one inch of water column.

Peak Flow Pump #3 VFD – Still waiting on fuses.

Heating/Air Conditioning Unit Solids Building Garage – New unit on order.

P K Boiler – Boiler has been installed and start up is complete.

Kevin Skogman  
Director of Operations & Maintenance