

## **Operations Update**

Plant Operations – Plant operations and treatment were OK during the month of April.

Process Control Technician/Operator – Recently interviewed an individual for the position and he accepted with a start date of Monday May 22nd.

## **Maintenance Update**

ACTI-FLO Water Champ – Recently replaced a water champ motor in the ACTI-FLO; these are used for the dispersion of ferric into the flow stream.

Turbine Pump #1 VFD – Still waiting on the heat sink fan retrofit kit.

Admin Building AHU Chilled Water Coil – New coil was received and installed.

Peak Flow Pump #3 VFD – Still waiting on fuses.

Heating/Air Conditioning Unit Solids Building Garage – New unit has arrived and is in the process of being replaced.

Kevin Skogman  
Director of Operations & Maintenance