

Operations Update

Plant Operations – Plant operations and treatment were good during the month of August.

Bio-Solids Hauling – Hauling started the week of August 7th with about 2.1 million gallons hauled with 1.3 million gallons yet to go. The haulers are now waiting for corn silage to come off some of the fields they have lined up. Contacted the hauler on 9/7 and they were told by the farmer about 10-14 days before hauling can begin again.

Maintenance Update

Biostyr Blower – Received the new blower and it has been put into service due to another blower failing. Have now sent the blower in that failed to see if it can be rebuilt. If it is beyond a rebuild another new one will have to be ordered.

ACTI-FLO Mixer – The mixer came in, was installed and put into service.

Rain Gauge (Darboy) – New rain gauge has arrived and will be installed when everything checks out ok.

Turbine Pump #1 VFD – Still waiting on the heat sink fan retrofit kit; the updated ETA is 9/25.

Kevin Skogman
Director of Operations & Maintenance