

Operations Update

Plant Operations – Plant operations and treatment were good during the month of September.

Bio-Solids Hauling – Badger State Waste came back on 9/20 to start hauling again and finished on 10/2. There was an additional 2.4 million gallons hauled out to make a grand total of 4.6 million gallons land applied. On the week of 10/16 the ATAD will be cleaned out.

Maintenance Update

Biostyr Blower – Last month I mentioned a new blower was put in due to another failing and that blower was going to be sent in for possible rebuild. The rebuild cost is more than a new blower, therefore another new blower is on order.

Rebuild - \$16,387 New - \$13,764

Rain Gauge (Darboy) – New rain gauge has been installed and is working good so far.

Turbine Pump #1 VFD – Received the heat sink fan retrofit kit; installed it and drive is back in operation.

Meter Station 5 South – Recently a leak was found in Meter Station 5 South on the inlet side. John Neumeier has been notified and he has Great Lakes TV & Seal hired to repair it.

Kevin Skogman
Director of Operations & Maintenance

