

Operations Update

Plant operations and treatment were good during the month of November.

Maintenance Update

Meter Station #9 Pump: Pump #1 was tripping at the breaker. The lead cable was deteriorated and split open causing a motor issue. Because of the age of the pump it was decided to replace it. The cost from Crane Engineering for a 4" Barnes pump is \$7,858.00. A new one has been ordered and should arrive in early January 2024.

Sludge Transfer Pump #1: The pump had a hole in one of the trunnions and lost pump efficiency. A full rebuild of the pump was completed at a cost of \$3,996.44.

Dustin Jerabek