

Darboy Sanitary District

2024 Flow Data

DAILY AVERAGE FLOW VOLUME (MGD):	1.04	
PEAK MONTHLY FLOW VOLUME (MGD):	1.20	
PEAK HOURLY FLOW VOLUME (MGD):	3.63	
PEAKING FACTOR RATIO (PEAK MONTHLY:ANNUAL DAILY AVERAGE):		1.15
PEAKING FACTOR RATIO (PEAK HOURLY:ANNUAL DAILY AVERAGE):		3.48
TOTAL PRECIPITATION FOR 2024 =	33.18	