

Village of Combined Locks

2025 Flow Data

DAILY AVERAGE FLOW VOLUME (MGD):	0.50	
PEAK MONTHLY FLOW VOLUME (MGD):	0.76	
PEAK HOURLY FLOW VOLUME (MGD):	1.89	
PEAKING FACTOR RATIO (PEAK MONTHLY:ANNUAL DAILY AVERAGE):		1.52
PEAKING FACTOR RATIO (PEAK HOURLY:ANNUAL DAILY AVERAGE):		3.77
TOTAL PRECIPITATION FOR 2025 =	19.75	